

Development Control
Burnley Borough Council

Tel 0300 123 6780
Email develooperas@lancashire.gov.uk

Your ref FUL/2021/0560
Our ref
Date 13th October 2021

Dear Sirs

Application no: 2021/0560

Location: Located on the eastern side of Palace Street on the footway adjacent the gable elevation of No. 42 Carter Street

Proposal: Erection of 15m pole, fibre cable, antennae and associated cabinets for the installation of high speed wireless internet.

With regard to the application I have the following comments to make based on all the information provided by the applicant to date.

The Highways Development Control section of Lancashire County Council has no objections to the proposals.

However, there are a number of points that we would wish to be taken in account during the installation of the equipment:

- No pole should be placed with-in 500mm of the kerb edge of the footway.
- Care should be taken to allow for the passage of mobility impaired residents on footways, guidance should be taken from the Department of Transport's document Inclusive Mobility, a clearance of 1800mm is preferred to allow for the passage of mobility scooters, where this cannot be maintained an absolute minimum of 1200mm should be maintained.
- Care should be taken placing poles in close proximity to street lighting columns, the supply cables to columns have little or no discernible current flowing through them during daylight hours nor are they substantial in construction and they are problematic to trace prior to any digging.

If you have any questions regarding my comments please do not hesitate to contact me.

Yours sincerely

Simon Hardie
Highways Development Control
Lancashire County Council

Phil Durnell

Director of Highways and Transport
Lancashire County Council
PO Box 100 · County Hall · Preston · PR1 0LD
www.lancashire.gov.uk